


EXCAVATING AND/OR TRENCHING

SJP-30

PURPOSE/APPLICATION

Trenching and/or excavating is a necessary task involved with the construction of a Pipeline or Facility, or any services that are underground. Trenching/Excavating may be done by hand or by mechanical means, depending on the size of the excavation.



#	Job Steps	Hazards	Control Measures
1	Pre-Plan the excavation or trench	 Miscommunication 	 Ensure you have looked at all aspects of the job
			 Communicate job plan with everyone involved
			 A competent Canadian Plains Energy Services representative must supervise any ground disturbance activities, be involved in ground disturbance pre-planning, and sign off on the ground disturbance permit(s)
2	Conduct a site-specific hazard assessment	 Unseen hazards (underground facility) 	 1st Call – call before you dig
		 Slips, Trips, Falls 	



SJP-30

April 18, 2018

EXCAVATING AND/OR TRENCHING

#	Job Steps	Hazards	Control Measures		
3	Obtain a Safe Work Permit (when necessary)				
4	Traffic Control – traffic must be controlled at roads and/or busy access ways	 Vehicle/Equipment Traffic Pedestrian Traffic 	Traffic controller in high visibility vestProper signage		
5	Prior to any excavation and/or trenching operation, all underground and/or overhead lines must be located, well marked and exposed in accordance with applicable OH&S legislation and other applicable regulations	 Line strikes Contact with overhead utilities 	 Contact power company when within 7 meters of any power lines Communicate hazards with everyone involved Signage or Goalposts to help identify hazard Hand expose underground facility using shovels or a hydro- vac unit 		
6	Ensure use of a spotter at all times while Trenching/Excavating	 Open Excavations Contact with equipment 	 Restrict access to area Stay out of swing radius of excavator Eye contact with operator at all times 		
7	Barricade Trench/Excavation when necessary and/or at the end of the workday	 Cuts, scrapes Open excavation Sloughing 	 Stay out of line of fire Use snow fence to barricade open excavations Use signage to communicate hazards 		



April 18, 2018

EXCAVATING AND/OR TRENCHING

ADDITIONAL PRECAUTIONS

Note: Reference AOH&S Regulations 442(1), (2), (3) & (4) for Classification of Soil Type definitions

- **Note:** Even though AOH&S legislation allows a 30 degree cut back in "hard and compact" soil, the CPES minimum cut back in all soil types is <u>45 degrees</u> from the vertical
- No worker may enter an excavation or trench that is more than 1.5 meters (5 ft) deep in Alta and Sask and 1.2 meters ((4ft) deep in BC, unless the worker is protected from cave ins or sliding or rolling materials by cutting back the walls, installing temporary protective structures or a combination of both.

Note: This does not apply if walls are solid rock throughout the entire length and width of each bank

- Determine side/end wall cut back
 - a) If the soil is classified as "hard and compact " or "likely to crack or crumble", the walls will be sloped to within 1.5 meters (5ft) of the bottom of the excavation/trench and at an angle of not less than <u>45 degrees</u> measured from the vertical
 - b) If the soil is classified as "soft, sandy or loose", the walls will be sloped from the bottom of the excavation/trench and at an angle of not less than <u>45 degrees</u> measured from the vertical
 - Determine spoil deposits
 - The leading edge of the spoil pile must be at least 1 meter (3ft) away from the edge of the excavation or trench and at an angle not more than 45 degrees from the horizontal
 - All loose materials must be scaled and trimmed from the side of an excavation and from the spoil pile to prevent such materials from accidentally falling into the excavation/trench
- **Note:** If the top of the spoil pile cannot be kept back a minimum of 1 meter (3ft) from the edge of an excavation/trench, then it becomes part of the total depth (i.e. Total depth = depth of excavation/trench + height of spoil pile)
 - Determine temporary protective structures
 - Where the cut back method of worker protection is not possible then temporary
 protective structures of sufficient strength to prevent the walls or spoil material from
 moving into the excavation must be installed
 - Where the excavation/trench is greater than 3 meters (10ft) deep and bank cut back to meet legislative requirements is not practical, then temporary protective structures must be installed. These structures must be designed and approved by a professional engineer
 - Determine entry and exit points
 - No worker shall enter an excavation or trench unless properly constructed entry/exit ramps or ladders, or a combination of both have been constructed and/or placed not more than 8 meters (26ft) from the worker(s)
 - All ladders must be capable of extending 1 meter (3ft) above the top of the banks or protective structures



April 18, 2018

EXCAVATING AND/OR TRENCHING

SJP-30

See Schedule A

Excavation and/or Trench Safety for Man Entry – Back sloping Requirements for Excavations and/or Trenches Over 1.5m Deep

See Schedule B

Excavation/Trench Safety for Man Entry and Exit – Ramps and/or Ladder.

REFERENCE/REGULATIONS •

- Alberta O H & S Act, Code & Regulations April 1, 2004
 - Code Part 32, Excavating and Tunneling
- Alberta Pipeline Act
 - Regulations(in particular) 20, 21 & 22
- CPES SWP/COP-03 Confined Space Entry
- CPES SWP 46Excavating to Locate and Expose Buried Facilities.
- CPES SWP 24 Overhead Power Lines (working near)
- Alberta 1st Call

Developed by:	1.	Carol Vincent (Consultant)	. <u></u>	Date:	Aug. 22, 2004
	2.	Wayne Pawsey		Date:	Nov. 2, 2001
Revised by:	1.	Jay Pilon		Date:	Apr. 20, 2010
	2.	Todd Penney		Date:	Aug. 24, 2012
	3.	Ryan Obleman		Date:	Apr. 18, 2018